

*Annual Drinking Water Quality Report for 2015
Village of Goshen Water Supply System
276 Main Street, Goshen, NY 10924
Public Water Supply ID #3503528*

INTRODUCTION

To comply with State and Federal regulations, the Village of Goshen will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Cynthia Ceconello, Plant Operator** at **(845) 294-5991**. We want you to be informed about your drinking water. If you would like to attend any of our regularly scheduled Village Board Meetings, they are held at 7:00 PM every 2nd and 4th Monday each month at the Village Hall, 276 Main Street, Goshen, New York.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants, inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our normal water source is Prospect and Green Hill Reservoirs. Prospect Reservoir is located along Reservoir Road and Green Hill Reservoir is located off Conkintown Road. Glenmere Lake is approved emergency source supply. The Crystal Run Wells were approved on November 26, 2014 as a permanent water source which is located in the Town of Walkkill.

This year our water system reservoirs were low and we used Crystal Run Wells in January to July and then September to December.

Water from Green Hill Reservoir was pumped into Prospect Reservoir. From Prospect Reservoir, water flows by gravity to the Village's water filter plant. After filtration, disinfection, pH adjustment and corrosion control treatment, the treated water enters the distribution system, which includes three water storage tanks.

FACTS AND FIGURES

Our water system serves approximately 5,500 people in the Village of Goshen through 1,750 service connections. The total water produced from all sources in 2015 was 239 million gallons. The daily average of water treated from all sources was 655,178 gallons per day. Our highest single day of water consumption was 888,400 gallons. The amount of water delivered to customers was 226 million gallons. This leaves an unaccounted total of 13 million gallons. This water was used to flush mains, fight fires, leakage, filter backwash and unaccounted losses. In 2015, the average annual charge per 1,000 gallons was \$4.80.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, total organic carbon, synthetic organic compounds, pesticide/PCB organics, herbicide organics, methylcarbanate pesticides, PCBs and radioactive contaminants.

The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the County of Orange Health Department at (845) 291-2331.

Filter Plant & Distribution system

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Turbidity ¹	No	6/5/15	0.22 (max)	NTU	N/A	TT= ≤ 1.0 NTU	Soil Runoff
Turbidity ¹	No	6/15	100%	NTU	N/A	TT=95% of samples ≤ 0.3 NTU	Soil Runoff
Copper ² (Distribution)	No	6/17/15	90 th = 0.12 Range = 10 to 200	mg/l	1.3	AL = 1.3	Corrosion of household plumbing systems
Lead ³ (Distribution)	No	6/17/15	90 th = 1.6 Range = ND to 2.6	ug/l	0	AL = 15	Corrosion of household plumbing systems
Total Trihalomethanes (TTHMs) (Distribution)	No	2015	Ave = 45.8 ⁴ Range = 22 to 69	ug/l	N/A	MCL = 80	Byproduct of drinking water disinfection needed to kill harmful organisms.
Five Haloacetic Acids (HAA5) (Distribution)	No	2015	Ave = 30.9 ⁴ Range = to	ug/l	N/A	MCL = 60	
Sodium	No	1/7/15	11	mg/l	N/A	See Note 5	Road Salt
Sulfate	No	1/7/15	11	mg/l	N/A	MCL = 250	Naturally occurring
Nickel	No	1/7/15	0.68	ug/l	100	MCL = 100	Erosion of natural deposits
Barium	No	1/7/15	0.0087	mg/l	2	MCL = 2	Erosion of natural deposits.
Total Coliform/ E.Coli Bacteria	YES	7/15	5 positive samples (4 E.coli +)	N/A	0	MCL = 2 positive samples / month	Naturally present in the environment

Crystal Run Wells

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Barium	No	2015	Ave = 0.26 0.24 – 0.27	mg/l	2	MCL = 2	Erosion of natural deposits.
Arsenic	No	2015	0.27	ug/l	N/A	MCL = 10	Erosion of natural deposits.
Nickel	No	2015	1.5 1.1 – 1.9	ug/l	100	MCL = 100	Erosion of natural deposits
Chromium	No	2015	7.0	ug/l	100	MCL = 100	Erosion of natural deposits
Sulfate	No	2015	59.5 59 – 60	mg/l	N/A	MCL = 250	Naturally occurring
Sodium	No	1/7/15	11	mg/l	N/A	See Note 5	Road Salt

1 - Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Effluent turbidity varied between 0.02 to 0.22 NTU. Our highest single turbidity measurement for the year occurred on 06/05/15 (0.18 NTU). State regulations require that turbidity must always be below 1 NTU. The regulations require that 95% of the turbidity samples collected have measurements below 0.3 NTU. In our case, 100% of the samples collected were below 0.3 NTU.

2 - The level presented represents the 90th percentile of the 25 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 25 samples were collected at your water system and the copper did not exceed in any of the samples. The action level for copper was not exceeded at any of the sites tested.

3 - The level presented represents the 90th percentile of the 25 samples collected. The action level for lead was not exceeded at any of the 25 sites tested.

4 - This level represents the highest locational running annual quarterly average calculated from data collected.

5 - Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Definitions

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of radioactivity in water.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

WHAT DOES THIS INFORMATION MEAN?

The table shows that our system uncovered some problems this year. During July of 2015 we had detections of Coliform and E. Coli during a single sampling event. The Village was placed on a boil water order during that time. The boil water order was lifted a few days later and all coliform samples since that time have been negative.

Some other analytes were detected during 2015; however, these contaminants were detected below the level allowed by the State.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2015, our system received a violation for a treatment technique, please see the attached notice regarding this TOC violation.

INFORMATION ON TOC

Total organic carbon has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes and haloacetic acids. Drinking water containing these byproducts in excess of the maximum contaminant level may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increase risk of getting cancer.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Our system is marginal and susceptible to water shortage created by dry spells. So there are a number of reasons why it is important to conserve water.

- Saving water saves energy and some of the costs associated with both of these necessities of life.
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, filtration systems, pumping systems chemicals and water towers
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15-20 gallons a day.
- Fix it up and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes; if moved, you have a leak.

SWAP SUMMARY BY NYSDOH

The NYSDOH has evaluated this PWS's susceptibility to contamination under the Source Water Assessment Program (SWAP), and their findings are summarized in the paragraph below. It is important to stress that these assessments were created using available information and only estimate the potential for source water contamination. Elevated susceptibility ratings do not mean that source water contamination has or will occur for this PWS. This PWS provides treatment and regular monitoring to ensure the water delivered to consumers meets all applicable standards.

The assessment area for this drinking water source from Greenhill Reservoir and Prospect Reservoir contains no discrete PCSs, and only the pastureland cover contaminant prevalence ratings is greater than low. This results in a high susceptibility rating for protozoa. However, the high mobility of microbial contaminants in reservoirs results in this drinking water intake also having medium-high susceptibility ratings for enteric bacteria and viruses. Furthermore, reservoirs are highly susceptible to water quality problems caused by phosphorus additions. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted in the report.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community; our way of life and our children's future. Please call our office if you have questions.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

The Village of Goshen Did Not Meet Treatment Requirements

Our water system recently violated a drinking water standard. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did to correct this situation.

As part of our Disinfection By-Products rule we routinely monitor for removal of Total Organic Carbon (TOC) in our filters. The running annual average of test results ending in the months of July 2015 through January of 2016 showed removal levels of TOC at 0.98, where 1.0 removal is required. Therefore, our supply is in violation for those months.

What does this mean?

This is not an emergency. If it had been you would have been notified immediately. *Total Organic Carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts. These byproducts include Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5s). Drinking water containing these byproducts in excess of the Maximum Contaminant Level (MCL) may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.*

It should be noted that this supply also monitors for TTHM's and HAA5s and these results have not exceeded the MCLs.

What should I do?

You do not need to boil your water or take other actions. However, if you have specific health concerns, consult your doctor.

People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers.

What happened? What was done?

Compliance is based on a Running Annual Average. Although the average has been below what is allowed the recent TOC removal requirements have been met and we expect that to continue in the future.

For more information, please contact the Village of Goshen Water Plant at 845-294-5991 or by mail at 276 Main Street, Goshen, NY 10924.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Village of Goshen.

State Water System ID#:3503528.

Date distributed: February 29, 2016